



ATC
06-010

АКРЕДИТОВАНА
КОНТРОЛНА
ОРГАНИЗАЦИЈА
SRPS ISO/IEC 17020:2002

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number:

T 1022

Strana / Page:

1/2

Na zahtev naručioca /
By the request of purchaser:

DELTA TERM Novopazarska 12,
11000 Beograd, Srbija/Serbia

preduzeto je/
set to:

kontrolisanje novog proizvoda
the new product inspection

u vezi sa Izveštajem o kontrolisanju /
in relation to Inspection report:

Broj / Number:

T 1022

sa dokumentima u prilogu/
with enclosed documents:

- Prospekt proizvoda /
Catalogue pages of product;
- Dokumentacija o proizvodu /
Product documentation;
- Izveštaj o ispitivanju IMP-CGT-LAB broj T 1022 /
Test report by IMP-CGT-LAB No. T 1022

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja /
the inspection object :

Kuglasta slavina za unutrašnje gasne instalacije
Ball valve for internal gas installations

proizveden od /
manufactured by :

GIACOMINI S.p.A,
28017 S.Maurizio d'Opaglia (Na) Italija/Italy

oznaka - tip - serija /
mark - type - series :

GIACOMINI R 850...

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements sa decribed in :

referentnom dokumentu /
reference document :

SRPS M.C5.452:1992

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2002 .
The inspection certificate is issued basis on the standard SRPS ISO/IEC 17020:2002 .

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa
periodičnim kontrolisanjem do dana /

Surveillance of the inspection object compliance is assured by periodical inspection until the date :

09.06.2015

INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15
BEOGRAD
SRBIJA
tel: +381 11 2772 151
fax: +381 11 2781 029
impcgt@labtel.imp.bg.ac.rs

mesto, datum / place, date

Beograd, 10.06.2010

Belgrade, 10th of June, 2010



izdat od / issued by :

RUKOVODIOCA CENTRA ZA GASNU TEHNIKU

GAS TECHNIQUE CENTRE MANAGER

mr. Vladeta Buljak, dip. ing.

Ime, Prezime / Name, Surname

Sertifikat o kontrolisanju Inspection certificate



ATC
06-010

АКРЕДИТОВАНА
КОНТРОЛНА
ОРГАНИЗАЦИЈА
SRPS ISO/IEC 17020:2002

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number:

T 1022

Strana / Page:

2/2

Prilog A /
Annex A

oznaka - tip - serija /
mark - type - series :

GIACOMINI R 850...

detaljno oznaka - tip - serija / mark - type - series designation :	tehničke karakteristike / <i>technical characteristics</i> :		opis / <i>description</i> :
	DN	navojni priključci / thread connections :	
GIACOMINI...			
...R850X003	15	R 1/2"	4 bar Metalna ručna zaporna kuglasta slavina za unutrašnje gasne instalacije, za pritiske do PN 4, sa punim prolazom, sa obostrano unutrašnjim navojnim priključcima / <i>Manually operated metallic ball shut-off valve for internal gas installations up to PN 4, with full bore, with internal thread connections on both sides</i>
...R850X004	20	R 3/4"	
...R850X005	25	R 1"	
...R850X006	32	R 1 1/4"	
...R850X007	40	R 1 1/2"	
...R850X008	50	R 2"	

Inspection certificate

Sertifikat o kontrolisanju

INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15
BEOGRAD
SRBIJA
tel: +381 11 2772 151
fax: +381 11 2781 029
impcgt@labtel.imp.bg.ac.rs